

**QUESTION(S) REGARDING THE RFP FOR THE LED RETROFIT PROJECT FOR KERR COUNTY**

**Question:** I noticed on the description of facility's to be quoted there where in addition to the ones with items listed also mentioned the Church and Airport facilities. Are these just being mentioned at this time as possible future projects or are you wanting and expecting these quoted by the 22nd as well. I do believe the last conversation we had was that everyone would bid on the facilities already surveyed and list provided but want to be sure.

**Answer:** Bid on only those facilities already surveyed.

**ADDITIONAL QUESTIONS – SUBMITTED ON 11/1/16 AT PRE-BID SITE VISIT**

What hours should we use for the energy calculations?

**Answer:**

Courthouse:	M-F 7:00 AM to 6:00 PM
Detention Center:	24/7
New Ag Barn:	3 days/week – 10 hours/day
Park & Restroom:	1 day/week – 8 hours
Probation Center:	M-F 7:00 AM to 6:00 PM
Wool Barn:	M-F 7:00 AM to 6:00 PM
Ag Extension Office:	M-F 7:00 AM to 6:00 PM
Jail:	24/7
Old Ag Barn:	3 days/week – 10 hours/day
Portable Classroom:	M-F 7:00 AM to 6:00 PM
Road & Bridge:	M-F 7:00 AM to 6:00 PM

What utility rates should we use for the energy calculations?

**Answer:** Current rate for power supply is 0.05329/KWH

**UPDATED INFORMATION!!! – Current rate is 0.04225/KWH**

Can we assume all ceiling heights will be accessible with a normal ladder?

**Answer:** You will need no greater than a 12' ladder

Can we assume the county will provide secure storage for the materials?

**Answer:** County will provide secure storage

Will the county or the contractor be responsible for the disposal and/or recycling of old material?

**Answer:** Contractor will be responsible for disposal

Are they applying for a rebate as part of the project? If so, who is responsible for coordinating the effort? County or Contractor? Which TDSP Services (Transmission and Distribution Service Provider the County?

**Answer:** No rebate will be used

Who is responsible for the fixture type and counts? I.E. if they are wrong, will the County issue a change order for the corrected number of fixtures?

**Answer:** Contractor is responsible for fixture type

Is the contractor expected to retrofit the emergency lighting system as well?

**Answer:** No

Will permits be required to complete the scope of work?

Answer: No

Is there an electrical code that must be followed? If so, what versions?

Answer: No